



3250 Linebaugh Rd.  
 Xenia, OH 45385  
 Telephone (800) 762-0040  
 FAX (937) 879-8425

**CEMENT  
MILL  
TEST**

**Cement Identified as:** Mortar Cement, Type N **Date:** 09/15/23  
**Production Dates:** July, 2023

PHYSICAL REQUIREMENTS	ASTM C 1329 SPECIFICATIONS Type N			RESULTS
(ASTM C430) 45-um sieve, % retained	Maximum	24		8
(ASTM C266) Time of Setting (Gillmore)				
Initial Set, minutes	Range	120 - 1000		195
Final Set, minutes				280
(ASTM C185) Air Content, %	Range	8-21		14
(ASTM C1506) Water Retention	Minimum	70		76
(ASTM C1072) Flexural Bond Strength (psi)	Minimum	70		85
(ASTM C109) Compressive Strength, psi (Mpa)				
7 Day	Minimum	500 ( 3.5 )		2170 ( 15.0 )
28 Day	Minimum	900 ( 6.2 )		2770 ( 19.1 )

We hereby certify that this cement conforms to all of the standard requirements for mortar cement in the above specification for the type specified. ASTM C1072 testing is performed by an independent testing firm and results are available upon request.

By: *Rusty Strader*

Physical Testing completed by: TL, JT  
 Chemical Testing completed by: CA, NC, KL, NM

Rusty Strader  
 Quality Control Manager  
 Fairborn Cement Company